

Sealed Quotations are invited by 31.12.2018 up to 13.00 PM for the following:

- 1) Supply of 10 KVA UPS Qty.: 01 NO.

Specifications for 10KVA UPS are as follows:

1. Capacity : 10 KVA online
2. I/P & O/P : 1 Phase
3. Back Up time : 30 min
4. Desired O/P voltage : 229 v.
5. With inbuilt isolation transformer
6. Static bypass disabled.
7. Battery Bank : 12 v 26 Ah : 22 Nos, with rack and links
8. Battery bank to UPS cable 2 meters.

Quotation should be in the name of

The Director

Indian Rubber Manufacturers Research Association (IRMRA)

(Affiliated to Ministry of Commerce And Industry, Govt. Of India)

Plot No. : 254/1B, Road No. 16V,

Wagle Industrial Estate,

Thane (W)- 400604.

Contact No. : 022- 67873244.

On the Envelope please mention "10 KVA UPS "